



Case Study
iSep[™] 500 UF
Produced Water
Treatment

Case Study: Industrial Produced Water Treatment

Cost-efficient treatment of produced and flow back waters using spiral-wound, polymeric UF membrane modules.



PROBLEM

Meeting sustainability goals in oil & gas exploration without losing performance



SITE

Oil & gas pilot system in the Midwest Region of the USA



OUTCOME

Highly effective and cost-efficient UF solution met sustainability goals

OBJECTIVE

Water scarcity and stricter discharge regulations are critical issues at the forefront of today's oil & gas industry. Fresh water is a critical resource needed for unconventional oil & gas exploration and is an important factor for future growth. In light of ongoing water issues, oil & gas producers have taken on new sustainability goals that place greater emphasis on water conservation and reuse.

MATERIALS & METHODS

iSep™ 500-PVDF ultrafiltration (UF) modules were operated directly downstream of primary oil removal steps in produced and flow back water treatment systems. The high quality effluent can be directly reused, discharged, or sent to reverse osmosis (RO) for further treatment.



RESULTS

iSep[™] UF membranes act as a distinct barrier layer that does not allow oil, suspended solids, or bacteria to pass through. The operating flux and effluent quality remained the same, even when drastic changes in the feed water occurred.

Oil levels in the feed reached as high as 300 mg/L (Figure 1) while suspended solids (TSS) reached as high as 1,000 mg/L. Despite these spikes, the *iSep* UF modules continued to operate at a stable flux of 51 l/mh (30 gfd). Undeterred by the spikes in the incoming water quality, the UF system provided consistent effluent quality – removing 99% oil, TSS, and bacteria (Table 1).

CONCLUSION

iSep 500 PVDF UF modules help oil producers achieve their sustainability goals by providing highly effective and cost-efficient treatment of produced and flow back waters. The high oil and solids tolerance of *iSep* UF membranes enables oil & gas producers to reuse produced and flow back waters, preserving valuable fresh water resources while reducing disposal costs.

Tables & Data

Parameters	Description
Oil & Grease	< 1.0 mg/L
Turbidity	< 0.1 NTU
Suspended Solids (TSS)	< 1.0 mg/L
Silt Density Index	< 2.0
Bacteria	Non-detect
Power Consumption	< 0.01 kW-hr per bbl
Chemical Consumption	< \$0.01 per bbl

Table 1 *iSep* 500[™] PVDF UF effluent quality



Figure 1 The operating flux remained stable at 51 l/mh (30 gfd) despite the spikes in influent oil (up to 300 mg/L).

